



- Note 1: The instrumentation shown is the minimum required. The purchaser may wish to specify additional devices.
- Note 2: For cooling medium other than water system design shall be mutually agreed upon between purchaser and the vendor.
- Note 3: See 6.13.
- Note 4: If a packing cooling console is not supplied, individual strainers are required (see 6.13.2.6).
- Note 5: Cooler to have vents and drains on both shell and tube side.
- Note 6: Normal level is above the highest point of the piping on the compressor cylinders.
- Note 7: The system shown is typical: more or less equipment may be provided.

Figure G-4—Typical Self-Contained Cooling System for Piston Rod Pressure Packing